

Main Office (352)567-0848
Fax number (352)567-6035
Hearing Impaired
Dial 7-1-1 for Florida relay



Jeff Sklet
Interim Executive Director

ADDENDUM NO.2

PCHA-IFB-2022-004 GENERAL CONTRACTOR SERVICES – MAGNOLIA OAKS NEW CONSTRUCTION

Date: September 8, 2022

The following changes, additions, and/or deletions are hereby made a part of the Documents for the above noted request for quotes, fully and completely as if the same were fully contained therein. All other terms, conditions, and specifications of the original Invitation for Bids, remain unchanged.

BID DUE DATE: September 16, 2022 by 2:00pm

Below is an additional link which will provide the revised and added Specifications

[http://ftp.gmcnetwork.com/main.html?download&weblink=602017252aac17e16b1a689264e0d4fa&realfilename=PCHA\\$20-\\$20Magnolia\\$20Oaks\\$20 \\$20RFIs\\$20\\$2301\\$2C\\$2003\\$20 \\$20Revised\\$20and\\$20Added\\$20Specifications.pdf](http://ftp.gmcnetwork.com/main.html?download&weblink=602017252aac17e16b1a689264e0d4fa&realfilename=PCHA$20-$20Magnolia$20Oaks$20 $20RFIs$20$2301$2C$2003$20 $20Revised$20and$20Added$20Specifications.pdf)

In regards to question #26,

26. The civil plans do not have fire lines run to the buildings. Please advise.


Response: Refer to sheet #17 and #18 Potable Water and Sanitary Sewer Plan for fire line and fire hydrant locations at both east and west side.

The 8" Main Water line feeding the Fire Hydrants and the building pads through both parcels is clearly shown on the civil plans. See page 2 for drawing.



"This institution is an equal opportunity provider and employer."





"This institution is an equal opportunity provider and employer."

